



Phone: 503-554-8333
 1-855-554-8333 (TF)
 Mail: P.O. Box 699
 Newberg, OR 97132
 Email: info@hilandwater.com
 Internet: www.hilandwater.com

December 4, 2023

Otter Rock Water District

Monthly Operations Report: November 2023

Diamond Maps Link - <https://diamondmaps.com/map.ashx?key=8054231204171035647>

Nov. preview: Spring flow – November 1, 2023

Source	Flow rate
Spring 1 flow rate	19
Spring 2 flow rate	5
Spring 3 flow rate	31
Reservoir overflow rate	12

Dec. preview: Spring flow – December 1, 2023

Source	Flow rate
Spring 1 flow rate	19
Spring 2 flow rate	9
Spring 3 flow rate	30
Reservoir overflow rate	18

Chlorine levels

	First User	Distribution System
Average	0.28 ppm	0.23 ppm
High	0.43 ppm	0.29 ppm
Low	0.22 ppm	0.18 ppm

Other notable activities during the month:

1. 11/7 Bacterial sample was collected and passed.
2. 11/14 Board Meeting
3. 11/28 Started meter splicing 230 and 415 1st st. Backfilled open holes.
 The crew found water flowing from 230 1st st and was concerned there was a leak near the corp stop which could lead to a full break if uncovered. They opted to door tag homes for a potential shut down on 11/29.
4. 11/29 The crew dug up the main line in preparation of uncovering a leak, but only found flowing groundwater. They spliced in new meters as normal.
 230 1st Street - SN : 95888494
 415 1st Street - SN : 95888497