



Phone: 503-554-8333
1-855-554-8333 (TF)
Mail: P.O. Box 699
Newberg, OR 97132
Email: info@hilandwater.com
Internet: www.hilandwater.com

August 1, 2023

Otter Rock Water District Monthly Operations Report: July 2023

Diamond Maps Link - <https://diamondMaps.com/map.ashx?key=8054230801122232196>

Spring flow – July 3, 2023

| Source | Flow rate |
|-------------------------|-----------|
| Spring 1 flow rate | 33 gpm |
| Spring 2 flow rate | 47 gpm |
| Spring 3 flow rate | 30 gpm |
| | |
| Reservoir overflow rate | 43 gpm |

June preview: Spring flow – August 1, 2023

| Source | Flow rate |
|-------------------------|-----------|
| Spring 1 flow rate | 26 gpm |
| Spring 2 flow rate | 31 gpm |
| Spring 3 flow rate | 31 gpm |
| | |
| Reservoir overflow rate | 29 gpm |

Chlorine levels

| | First User | Distribution System |
|---------|------------|---------------------|
| Average | 0.24 ppm | 0.25 ppm |
| High | 0.31 ppm | 0.38 ppm |
| Low | 0.2 ppm | 0.2 ppm |

Other notable activities during the month:

7/3 - Leak check at 6735 Gladys Ave.

7/4 - Bacterial test was taken and passed.

7/10 - Received a call from OHA about the Sweets coffee shop water outage concerns. Called the coffee shop to try and clarify and calm their concerns.

7/12-14 - Meter splicing. Worked through many large roots and difficult terrain.

7/21 - Meter splicing

7/26-28 - Meter splicing

7/28 - New service install at 6420 Nellie Ave