



Phone: 503-554-8333
 1-855-554-8333 (TF)
 Mail: P.O. Box 699
 Newberg, OR 97132
 Email: info@hilandwater.com
 Internet: www.hilandwater.com

October 17, 2024

Otter Rock Water District
Monthly Operations Report: September 2024
<https://diamondMaps.com/map.ashx?key=11003241008130558111>

September: Spring flow – September 1, 2024

Source	Flow rate
Spring 1 flow rate	24
Spring 2 flow rate	26
Spring 3 flow rate	31
Reservoir overflow rate	26

October. preview: Spring flow – October 1, 2024

Source	Flow rate
Spring 1 flow rate	21
Spring 2 flow rate	17
Spring 3 flow rate	31
Reservoir overflow rate	23

Chlorine levels

	First User	Distribution System
Average	0.28 ppm	0.28 ppm
High	0.30 ppm	0.40 ppm
Low	0.24 ppm	0.20 ppm

Other notable activities during the month:

1. 9/2 Meter read system.
2. 9/17 Collected Bac T sample.
3. 9/26 Replaced leaking spigot on district building.