



Phone: 503-554-8333
1-855-554-8333 (TF)
Mail: P.O. Box 699
Newberg, OR 97132
Email: info@hilandwater.com
Internet: www.hilandwater.com

June 3, 2023

Otter Rock Water District Monthly Operations Report: May 2023

Spring flow – May 1, 2023

| Source | Flow rate |
|-------------------------|-----------|
| Spring 1 flow rate | 64 gpm |
| Spring 2 flow rate | 180 gpm |
| Spring 3 flow rate | 31 gpm |
| | |
| Reservoir overflow rate | 150 gpm |

June preview: Spring flow – June 1, 2023

| Source | Flow rate |
|-------------------------|-----------|
| Spring 1 flow rate | 39 gpm |
| Spring 2 flow rate | 82 gpm |
| Spring 3 flow rate | 31 gpm |
| | |
| Reservoir overflow rate | 90 gpm |

Chlorine levels

| | First User | Distribution System |
|---------|------------|---------------------|
| Average | 0.21 ppm | 0.26 ppm |
| High | 0.25 ppm | 0.36 ppm |
| Low | 0.16 ppm | 0.2 ppm |

Other notable activities during the month:

5/19 - Locate meter valve and Courtesy water shut off at 765 3rd st.

5/24 - Repaired broken serviceline at 915 1st st.

5/25 - Uncovered lines for meter splicing

5/31 - Spliced in 9 new meters on 1st Street, A Ave and B Ave.