



Phone: 503-554-8333  
 1-855-554-8333 (TF)  
 Mail: P.O. Box 699  
 Newberg, OR 97132  
 Email: [info@hilandwater.com](mailto:info@hilandwater.com)  
 Internet: [www.hilandwater.com](http://www.hilandwater.com)

August 5, 2024

## Otter Rock Water District Monthly Operations Report: July 2024

<https://diamondMaps.com/map.ashx?key=11003240805121226899>

July: Spring flow – July 1, 2024

Source	Flow rate
Spring 1 flow rate	30
Spring 2 flow rate	69
Spring 3 flow rate	41
Reservoir overflow rate	60

August. preview: Spring flow – August 1, 2024

Source	Flow rate
Spring 1 flow rate	30
Spring 2 flow rate	41
Spring 3 flow rate	30
Reservoir overflow rate	50

Chlorine levels

	First User	Distribution System
Average	0.27 ppm	0.25 ppm
High	0.34 ppm	0.34 ppm
Low	0.21 ppm	0.20 ppm

Other notable activities during the month:

1. 7/1 Meter read system.
2. 7/2 Collected Bac T sample
3. 7/9 Courtesy shut off at 6240 C St.
4. 7/24 Meter splicing
5. 7/25 Meter splicing
6. 7/31 Meter splicing & LCRR