



Phone: 503-554-8333  
 1-855-554-8333 (TF)  
 Mail: P.O. Box 699  
 Newberg, OR 97132  
 Email: [info@hilandwater.com](mailto:info@hilandwater.com)  
 Internet: [www.hilandwater.com](http://www.hilandwater.com)

April 4, 2024

## Otter Rock Water District Monthly Operations Report: April 2024

<https://diamondMaps.com/map.ashx?key=11003240503152450388>

April : Spring flow – April 1, 2024

| Source                  | Flow rate |
|-------------------------|-----------|
| Spring 1 flow rate      | 60        |
| Spring 2 flow rate      | 180       |
| Spring 3 flow rate      | 33        |
|                         |           |
| Reservoir overflow rate | 100       |

April. preview: Spring flow – April 1, 2024

| Source                  | Flow rate |
|-------------------------|-----------|
| Spring 1 flow rate      | 30        |
| Spring 2 flow rate      | 180       |
| Spring 3 flow rate      | 45        |
|                         |           |
| Reservoir overflow rate | 90        |

Chlorine levels

|         | First User | Distribution System |
|---------|------------|---------------------|
| Average | 0.30 ppm   | 0.28 ppm            |
| High    | 0.43 ppm   | 0.37 ppm            |
| Low     | 0.23 ppm   | 0.21 ppm            |

Other notable activities during the month:

1. 4/1 Meter read the system.
2. 4/2 Collected Bac T Sample.
3. 4/4 Searched for service line and corp stop at 615 3rd st.
4. 4/15 Searched again for 615 3rd st shut off.
5. 4/24 Shut off 615 3rd st, locate 125 Mahala Way.
6. 4/24 LCRR, prepped four addresses for meter installations.
7. 4/30 Turned water on at 615 3rd st.