



Phone: 503-554-8333
1-855-554-8333 (TF)
Mail: P.O. Box 699
Newberg, OR 97132
Email: info@hilandwater.com
Internet: www.hilandwater.com

February 1, 2024

Otter Rock Water District Monthly Operations Report: January 2024

<https://diamondMaps.com/map.ashx?key=8054240202102526507>

Jan. : Spring flow – January 1, 2024

Source	Flow rate
Spring 1 flow rate	47
Spring 2 flow rate	113
Spring 3 flow rate	30
Reservoir overflow rate	100

Feb. preview: Spring flow – February 1, 2024

Source	Flow rate
Spring 1 flow rate	113
Spring 2 flow rate	300
Spring 3 flow rate	38
Reservoir overflow rate	100

Chlorine levels

	First User	Distribution System
Average	0.22 ppm	0.25 ppm
High	0.31 ppm	0.44 ppm
Low	0.00 ppm	0.00 ppm

Other notable activities during the month:

1. 1/1 Meter read the system
2. 1/9 Bacteria sample was collected
3. 1/11 Inspected district for downed trees near S Gladys
4. 1/15 Power was lost to the system.
5. 1/16 Boil Water notice Issues
6. 1/17 Special sample was taken and passed.