



Phone: 503-554-8333
1-855-554-8333 (TF)
Mail: P.O. Box 699
Newberg, OR 97132
Email: info@hilandwater.com
Internet: www.hilandwater.com

July 5, 2023

Otter Rock Water District Monthly Operations Report: June 2023

Diamond Maps Link - <https://diamondMaps.com/map.ashx?key=8054230705170616921>

Spring flow – June 1, 2023

Source	Flow rate
Spring 1 flow rate	39 gpm
Spring 2 flow rate	82 gpm
Spring 3 flow rate	31 gpm
Reservoir overflow rate	90 gpm

June preview: Spring flow – July 3, 2023

Source	Flow rate
Spring 1 flow rate	33 gpm
Spring 2 flow rate	47 gpm
Spring 3 flow rate	30 gpm
Reservoir overflow rate	43 gpm

Chlorine levels

	First User	Distribution System
Average	0.22 ppm	0.28 ppm
High	0.25 ppm	0.38 ppm
Low	0.18 ppm	0.2 ppm

Other notable activities during the month:

6/23 - Leak check at 6810 gladys ave.

6/13 - Collected two sets of DBP samples and coli sample.

6/15 - Placing order for new meters (Ferguson)

6/28 - Ordering parts for meter splicing from Consolidated, Ferguson, and Grainger.

6/29 - Locate at 6735 gladys ave.