



Phone: 503-554-8333
1-855-554-8333 (TF)
Mail: P.O. Box 699
Newberg, OR 97132
Email: info@hilandwater.com
Internet: www.hilandwater.com

November 14, 2022

Otter Rock Water District Monthly Operations Report: October 2022

Spring flow – November 1, 2022

Source	Flow rate
Spring 1 flow rate	23 gpm
Spring 2 flow rate	24 gpm
Spring 3 flow rate	20 gpm
Reservoir overflow rate	32 gpm

Chlorine levels

	First User	Distribution System
Average	0.22 ppm	0.23 ppm
High	0.29 ppm	0.34 ppm
Low	0.16 ppm	0.15 ppm

Other notable activities during the month:

Preparation for the sanitary survey conducted by Lincoln County on October 21 with Curtis Olson was completed, including drafting an O&M manual and preparing all necessary documents. Lincoln County provided a report after the survey indicating no significant deficiencies other than missing lab results for water samples to test asbestos and IOC's. Since neither sample is required to be taken before the end of 2028, Hiland staff have informally challenged this assessment and Lincoln County is reviewing the schedules and rules to determine whether they should revise their report.

Cody Scott turned on water at 6715 Otter Crest Loop on October 19, 2022.