



Phone: 503-554-8333
1-855-554-8333 (TF)
Mail: P.O. Box 699
Newberg, OR 97132
Email: info@hilandwater.com
Internet: www.hilandwater.com

December 6, 2022

Otter Rock Water District Monthly Operations Report: November 2022

Spring flow – November 1, 2022

Source	Flow rate
Spring 1 flow rate	23 gpm
Spring 2 flow rate	15 gpm
Spring 3 flow rate	30 gpm
Reservoir overflow rate	7 gpm

[Spring flow – December 1, 2022: Spr 1 – 26.5; Spr 2 – 18; Spr 3 - 30]

Chlorine levels

	First User	Distribution System
Average	0.17 ppm	0.17 ppm
High	0.30 ppm	0.26 ppm
Low	0.00 ppm	0.00 ppm

Other notable activities during the month:

Lincoln County issued a revised report from their visit stating that there were no sampling deficiencies, but requested that samples for IOC's and asbestos be taken soon since the last samples were taken early on in the previous sampling cycle.

A water leak was repaired on November 17.

Staff built a block base for a vault to enclose the master flow meter.