ORWD Superintendent's Report: December, 2020

SPRINGS: We used water from Spring #2 and spring #1 this month and it was sufficient-see water—usage report. Water use = 20,933GPD—5 gal tub measurement =spring #1: 60GPM, 86,400GPD—Spring#2= 239GPM, 344,000—Total=430,000GPD

Tests for Total Coliforms and for E. Coli taken on 12/16/20

The initial test was negative for Total Coliforms and negative for E. Coli.

Meters: 0 meters were completed this month.

Meetings:

Leak Detection/Repair:

Locates: 0 locates

Safety Meeting: No new safety issues.

SUPERINTENDENT REPORT USAGE REPORT TABLE

MONTH/YEAR	YEAR			TOTAL USAGE FOR MONTH
January	2	2020	381,000	295,000
December	2	2020	72,000	628,000
November	2	2020	430,000	549,000
October	2	2020	38,592	709,000
September	2	2020	42,000	845,000
August	2	2020	61,000	1,101,000
July	2	2020	61,000	1,228,000
June	2	2020	72,000	756,000
Мау	2	2020	131,000	506,000
April	2	2020	198,000	719,000
March	2	2020	255,000	542,000
February	Ź	2020	535,000	434,000

Spring outflow this mo. compared to last year
Usage this month compared to last year