

ORWD Superintendent's Report: June, 2020

SPRINGS: We used water from Spring #2 and spring #1 this month and it was sufficient-see water usage report. Spring Flow = 1 1/4" = 72,000 GPD Water use = 756,000 GPM

Tests for Total Coliforms and for E. Coli taken on 6/16/2020

The initial test was positive for Total Coliforms and negative for E. Coli. The test was taken at the state park, we resampled five locations on 6/19/20. State park, community hall, fire station, spring #1 and spring #2. All samples came back negative except state park and spring #2. This triggered a level two investigation.

Meters: 3 meters were completed this month.

Meetings: During this month I met with: Lincoln Co.

Leak Detection/Repair:

Locates:

Safety Meeting: No new safety issues.

SUPERINTENDENT REPORT USAGE REPORT TABLE

MONTH/YEAR	YEAR	OVERFLOW gallons per day	TOTAL USAGE FOR MONTH
January	2020	381,000	295,000
December	2019	72,000	626,000
November	2019	17,000	549,000
October	2019	17,000	528,000
September	2019	42,000	677,000
August	2019	42,000	891,000
July	2019	52,000	954,000
June	2020	72,000	756,000
May	2020	131,000	506,000
April	2020	198,000	719,000
March	2020	255,000	542,000
February	2020	535,000	434,000
Spring outflow this mo. compared to last year	same		
Usage this month compared to last year	-138,000		