



Phone: 503-554-8333
 1-855-554-8333 (TF)
 Mail: P.O. Box 699
 Newberg, OR 97132
 Email: info@hilandwater.com
 Internet: www.hilandwater.com

April 7, 2023

Otter Rock Water District Monthly Operations Report: March 2023

Spring flow – March 1, 2023

Source	Flow rate
Spring 1 flow rate	45 gpm
Spring 2 flow rate	90 gpm
Spring 3 flow rate	32 gpm
Reservoir overflow rate	100 gpm

March preview: Spring flow – April 1, 2023

Source	Flow rate
Spring 1 flow rate	50 gpm
Spring 2 flow rate	150 gpm
Spring 3 flow rate	32 gpm
Reservoir overflow rate	100 gpm

Chlorine levels

	First User	Distribution System
Average	0.25 ppm	0.26 ppm
High	0.31 ppm	0.37 ppm
Low	0.21 ppm	0.21 ppm

Other notable activities during the month:

3/9/23 Cody performed a courtesy water shut off at 325 3rd St.

3/23/23 Cody performed a courtesy water shut off at 6625 Gladys's.

3/27/23 Curtis and Cody worked to temporarily repair a broken serviceline at 140 Mahala. Because this line was broken from locates not being marked, Otter Rock will not be charged for the repair.