



Phone: 503-554-8333
 1-855-554-8333 (TF)
 Mail: P.O. Box 699
 Newberg, OR 97132
 Email: info@hilandwater.com
 Internet: www.hilandwater.com

October 6, 2023

Otter Rock Water District Monthly Operations Report: September 2023

Diamond Maps Link - <https://diamondMaps.com/map.ashx?key=8054231006171932678>

Spring flow – September 1, 2023

Source	Flow rate
Spring 1 flow rate	23 gpm
Spring 2 flow rate	17 gpm
Spring 3 flow rate	31 gpm
Reservoir overflow rate	7 gpm

Sep. preview: Spring flow – October 1, 2023

Source	Flow rate
Spring 1 flow rate	20
Spring 2 flow rate	17
Spring 3 flow rate	30
Reservoir overflow rate	4.5

Chlorine levels

	First User	Distribution System
Average	0.25 ppm	0.25 ppm
High	0.31 ppm	0.28 ppm
Low	0.2 ppm	0.2 ppm

Other notable activities during the month:

9/5/23 - The monthly bacterial test was taken and submitted

9/7/23 - Meeting with Curtis, Bryce, Cody and Craig to ensure we could turn on Spring 3 if needed.

9/8/23 - Locate at 6875 Ellie

9/13/23 - Courtesy water turn off/on at 6885 Otter Crest Loop.

9/26-9/28 - Meter splicing

1. 6885 Otter Crest Loop (New SN : 95888480)
2. 165 3rd St. (New SN : 95888500)
3. 6820 Gladys Ave. (New SN : 95888501)
4. 6635 Gladys Ave. (New SN : 95888498)
5. 6910 Otter Crest Lp. (New SN : 95888499)