



Phone: 503-554-8333
1-855-554-8333 (TF)
Mail: P.O. Box 699
Newberg, OR 97132
Email: info@hilandwater.com
Internet: www.hilandwater.com

May 2, 2023

Otter Rock Water District Monthly Operations Report: April 2023

Spring flow – April 1, 2023

Source	Flow rate
Spring 1 flow rate	50 gpm
Spring 2 flow rate	150 gpm
Spring 3 flow rate	32 gpm
Reservoir overflow rate	100 gpm

May preview: Spring flow – May 1, 2023

Source	Flow rate
Spring 1 flow rate	64 gpm
Spring 2 flow rate	180 gpm
Spring 3 flow rate	31 gpm
Reservoir overflow rate	150 gpm

Chlorine levels

	First User	Distribution System
Average	0.2 ppm	0.24 ppm
High	0.35 ppm	0.3 ppm
Low	0.26 ppm	0.19 ppm

Other notable activities during the month:

4/6/23 - Installed the permanent fix for the broken service line on Mahala and backfilled. The district will not be charged for this work because it was our mistake that it was broken in the first place.

4/25 Service lines were exposed on Ellie and Gladys in preparation of meter splicing

4/27 New meters were spliced into existing lines at 6655 Ellie, 6740 Ellie, 6865 Ellie, and 6625 Gladys.

4/28 Checked on possible leak at Mahala on Otter Crest Rd. Couldn't determine if it was a leak or not.

4/28 Cody performed a courtesy shut off and turn on for 325 3rd st.