



Phone: 503-554-8333  
 1-855-554-8333 (TF)  
 Mail: P.O. Box 699  
 Newberg, OR 97132  
 Email: [info@hilandwater.com](mailto:info@hilandwater.com)  
 Internet: [www.hilandwater.com](http://www.hilandwater.com)

December 4, 2023

## Otter Rock Water District Monthly Operations Report: December 2023

**Diamond Maps Link - <https://diamondMaps.com/map.ashx?key=11003240102124226971>**

Nov. preview: Spring flow – December 1, 2023

Source	Flow rate
Spring 1 flow rate	19
Spring 2 flow rate	9
Spring 3 flow rate	30
Reservoir overflow rate	18

Dec. preview: Spring flow – January 1, 2024

Source	Flow rate
Spring 1 flow rate	47
Spring 2 flow rate	113
Spring 3 flow rate	30
Reservoir overflow rate	100

### Chlorine levels

	First User	Distribution System
Average	0.22 ppm	0.23 ppm
High	0.30 ppm	0.30 ppm
Low	0.17 ppm	0.19 ppm

Other notable activities during the month:

1. 12/1 Meter read the system
2. 12/5 Added the new 21 spliced meters to the meter reading sheet
3. 12/12 Board Meeting
4. 12/13 Bacterial sample was collected and passed.