



Phone: 503-554-8333
 1-855-554-8333 (TF)
 Mail: P.O. Box 699
 Newberg, OR 97132
 Email: info@hilandwater.com
 Internet: www.hilandwater.com

April 4, 2024

Otter Rock Water District Monthly Operations Report: March 2024

<https://diamondMaps.com/map.ashx?key=11003240404135409279>

March : Spring flow – March 1, 2024

Source	Flow rate
Spring 1 flow rate	60
Spring 2 flow rate	180
Spring 3 flow rate	30
Reservoir overflow rate	113

April. preview: Spring flow – April 1, 2024

Source	Flow rate
Spring 1 flow rate	60
Spring 2 flow rate	180
Spring 3 flow rate	33
Reservoir overflow rate	100

Chlorine levels

	First User	Distribution System
Average	0.23 ppm	0.25 ppm
High	0.25 ppm	0.34 ppm
Low	0.20 ppm	0.22 ppm

Other notable activities during the month:

1. 3/1 Meter read the system
2. 3/5 Collected Bac T Sample
3. 3/20 Located 6921 Ellie
4. 3/25 Courtesy Shut off 615 3rd St. Scheduled Corp replacement. Unfortunately, there was no shut off available so we rescheduled with the homeowner to uncover it on 3/28.
5. 3/28 Searched for Corp stop at 615 3rd using metal detector, maps and vac trailer. Discovered the line could potentially be 8 ft deep and unlocatable. Spoke with the homeowner again and made plans to splice in a new water service shut off.