



Phone: 503-554-8333
1-855-554-8333 (TF)
Mail: P.O. Box 699
Newberg, OR 97132
Email: info@hilandwater.com
Internet: www.hilandwater.com

July 13, 2022

Otter Rock Water District Monthly Operations Report: June 2022

Spring flow – June 2, 2022

Source	Flow rate
Spring 1 flow rate	69 gpm
Spring 2 flow rate	180 gpm
Spring 3 flow rate	36 gpm
Reservoir overflow rate	129 gpm

Chlorine levels

	First User	Distribution System
Average	0.23 ppm	0.23 ppm
High	0.30 ppm	0.37 ppm
Low	0.16 ppm	0.07 ppm

Other notable activities during the month:

On June 16, Curtis Olson was assigned as the primary contact for Otter Rock Water District.

The Annual Water Quality Report (CCR) was completed for 2021.

Hiland received notification of upcoming clearcutting in the area and corresponded with the Toledo Forestry Department regarding potential impact on the water system.

A landslide occurred in the area. Hiland personnel evaluated the impact on water system and suggested plans for remediation.

Systemwide flushing was performed and GPS coordinates for various points in the system were gathered on June 24.

Curtis researched possible options to repair the scissor hydrants. Through correspondence with Seattle Public Works, he learned that repairing those hydrants are no longer an option.

A new service agreement for service from Hiland beginning July 1, 2022 was drafted.