



Phone: 503-554-8333
 1-855-554-8333 (TF)
 Mail: P.O. Box 699
 Newberg, OR 97132
 Email: info@hilandwater.com
 Internet: www.hilandwater.com

September 7, 2024

Otter Rock Water District Monthly Operations Report: August 2024

<https://diamondMaps.com/map.ashx?key=11003240805121226899>

August: Spring flow – August 1, 2024

Source	Flow rate
Spring 1 flow rate	30
Spring 2 flow rate	41
Spring 3 flow rate	30
Reservoir overflow rate	50

September. preview: Spring flow – September 1, 2024

Source	Flow rate
Spring 1 flow rate	24
Spring 2 flow rate	26
Spring 3 flow rate	31
Reservoir overflow rate	26

Chlorine levels

	First User	Distribution System
Average	0.33 ppm	0.34 ppm
High	0.40 ppm	0.49 ppm
Low	0.24 ppm	0.23 ppm

Other notable activities during the month:

1. 8/1 Meter read system.
2. 8/14 Meter splicing
3. 8/20 Collected Bac T sample
4. 8/26 Meter splice prep and landscaping