## ORWD Superintendent's Report: March, 2021

**SPRINGS:** We used water from spring #1 this month and it was sufficient-see water usage report. Water use = 25,400GPD Weir:  $1\frac{1}{2}$  Total=95,000GPD

Tests for Total Coliforms and for E. Coli taken on 3/3/21 and 3/17/21

Both Tests was negative for Total Coliforms and negative for E. Coli.

**Meters:** 0 meters were completed this month.

Meetings:

Leak Detection/Repair: Locates: 2 locates

Safety Meeting: No new safety issues.

## SUPERINTENDENT REPORT USAGE REPORT TABLE

MONTH/YEAR	YEAR	OVERFLOW gallonsTOTA per day FOR		USAGE ONTH
January		2021	403,000	586,000
December		2020	430,000	628,000
November		2020	118,000	549,000
October		2020 38	,592	709,000
September		2020	42,000	845,000
August		2020	61,000	1,101,000
July		2020	61,000	1,228,000
June		2020	72,000	756,000
Мау		2020	131,000	506,000
April		2020	198,000	719,000
March		2021	95,000	762,000
February		2021	348,000	669,000