



Phone: 503-554-8333
 1-855-554-8333 (TF)
 Mail: P.O. Box 699
 Newberg, OR 97132
 Email: info@hilandwater.com
 Internet: www.hilandwater.com

June 5, 2024

Otter Rock Water District
Monthly Operations Report: May 2024
<https://diamondMaps.com/map.ashx?key=11003240605123125376>

May : Spring flow – May 1, 2024

Source	Flow rate
Spring 1 flow rate	30
Spring 2 flow rate	180
Spring 3 flow rate	45
Reservoir overflow rate	90

June. preview: Spring flow – June 3, 2024

Source	Flow rate
Spring 1 flow rate	30
Spring 2 flow rate	112
Spring 3 flow rate	45
Reservoir overflow rate	90

Chlorine levels

	First User	Distribution System
Average	0.33 ppm	0.31 ppm
High	0.52 ppm	0.45 ppm
Low	0.23 ppm	0.22 ppm

Other notable activities during the month:

1. 5/1 Meter read system.
2. 5/7 Collected Bac T Sample.
3. 5/15 Meter splicing project.
4. 5/16 Installed new lock box for Gate.
5. 5/28 Collected SOC, VOC & RAD Samples.
6. 5/29 Continued Meter splicing.