



Phone: 503-554-8333  
1-855-554-8333 (TF)  
Mail: P.O. Box 699  
Newberg, OR 97132  
Email: [info@hilandwater.com](mailto:info@hilandwater.com)  
Internet: [www.hilandwater.com](http://www.hilandwater.com)

October 7, 2022

## Otter Rock Water District Monthly Operations Report: September 2022

Spring flow – September 1, 2022

Source	Flow rate
Spring 1 flow rate	30 gpm
Spring 2 flow rate	39 gpm
Spring 3 flow rate	32 gpm
Reservoir overflow rate	47 gpm

Chlorine levels

	First User	Distribution System
Average	0.18 ppm	0.23 ppm
High	0.20 ppm	0.30 ppm
Low	0.15 ppm	0.15 ppm

Other notable activities during the month:

Aaron Olson and Cody Scott installed a curtain drain by spring #1.

Mel Olson collected a disinfection byproduct sample (DBP) on September 27. This sample is required annually in September due to the chlorination of the water.

The following water meters were installed by Curtis Olson, Matt Jackson, and Cody Scott for previously unmetered properties:

Date	Address	Meter Serial #
September 9, 2022	330 1 <sup>st</sup> Street	87433098
September 9, 2022	6815 Gladys	87433097
September 9, 2022	6810 Mitzy	898458685

Parts for these installations were used from the Otter Rock Supply and a few types of parts were re-stocked, including angle stops and couplings.